

PV-LOK[™] Series PWP for Bell Joint Restraint (CIOD)



Features & Advantage

The PV-LOK[™] Series PWP restrainer incorporates a series of machined serrations that effectively engage PVC pipe walls, to provide positive joint security and full support of the pipe. The directional gripping action maximizes restraint during increased line pressures such as those resulting from surges and water hammers. The Series PWP incorporates two PV-LOK clamping rings and a series of restraining rods & nuts that tie the two rings together and secure the PVC bell and spigot pipe joint.

Sample Specification:

Restraint devices for bell and spigot joints of PVC pipe shall consist of two split retainer rings incorporated a series of machined (not "as cast") serrations. One clamping ring shall be installed on the spigot pipe, and with the necessary restraining rods and nuts, connected to a second clamping ring located on the pipe barrel immediately behind the gasket bell. Restraint devices shall incorporate a series of machined serrations that provide positive restraint, exact fit and full support of the pipe wall. The restraint device shall provide the necessary bolts and nuts to complete the PVC pipe bell assembly. Devices shall carry a minimum 2:1 safety factor and meet or exceed the recognized testing for restrained joints on PVC pressure pipe and offer factory certification and independent test results. Restraint devices for securing PVC pipe bell assemblies shall be SIGMA PV-LOK[™] Series PWP or approved equal.

Material:

- Clamping ring is manufactured of high strength ductile iron in accordance with ASTM A536, grade 65-45-12.
- Side clamping bolt and hex nuts are high strength steel in accordance with ASTM A449 and zinc plated to B633, Type III Sc.1 for corrosion resistance.
- Restraining rods and hex nuts are of high strength, low alloy steel in accordance with AWWA/ANSI C111/A21.11 and provide a minimum 45,000 psi yield and 60,000 psi tensile strength.



Cross Section of PV-LOK illustrates directional grip of serrations to maximize restraint of PVC pipe



SIGMA Corporation

700 Goldman Drive Cream Ridge, NJ 08514 609 758 1163 f crm-sales@sigmaco.com www.sigmaco.com

PV-LOK[™] Series PWP for Bell Joint Restraint (CIOD)



- 1. Plain End Pipe
- 2. Restrainer Clamp
- 3. Bell End Pipe
- 4. Restraining Rod

Dimensions in Inches, Weights in Pounds:

Pipe Size	ltem #	PVC pipe w DI Pipe OD	А	в	C (max)	BCD		Restraining Rods		Nuts for Res Rods		Clamping Bolts			Weight
						Max	Min	No.	Size	No.	Size	No.	Size	Min Torque	Weight
4	PWP-C4	4.80	1.20	9.00	13.00	7.5"	7.12"	2	3/4x15	4	3/4	4	5/8x3 3/8	85	14.36
6	PWP-C6	6.90	1.20	11.52	13.00	10.02"	9.26"	2	3/4x18	4	3/4	4	5/8x3 3/8	85	16.44
8	PWP-C8	9.05	1.75	12.81	13.00	12.5"	11.5"	2	3/4x18	4	3/4	4	3/4x3 7/8	100	27.00
10	PWP-C10	11.10	1.75	16.88	16.00	15.26"	13.76"	4	3/4x24	8	3/4	4	7/8x4 3/8	125	44.40
12	PWP-C12	13.20	1.75	19.12	22.00	17.5"	16.00"	4	3/4x24	8	3/4	4	7/8x4 3/8	125	50.64
14	PWP-C14	15.30	3.50	21.10	22.00	19.6"	17.6"	6	3/4x30	12	3/4	8	7/8x6 1/4	130	101.61
16	PWP-C16	17.40	3.50	23.58	22.00	22.0"	20.0"	6	3/4x30	12	3/4	8	7/8x6 1/4	130	114.15
18	PWP-C18	19.50	4.25	25.80	22.00	24.04"	22.2"	8	3/4x30	16	3/4	8	1.00x6 1/4	130	164.97
20	PWP-C20	21.60	5.00	29.06	22.00	26.74"	24.70"	8	3/4x36	16	3/4	8	1-1/4x6-1/2	130	234.50
24	PWP-C24	25.80	5.00	34.64	22.00	32.36"	29.72"	10	3/4x36	20	3/4	8	1-1/4x6-1/2	130	288.50
30	PWP-C30	32.00	5.50	41.80	38.00	39.76"	36.76"	10	1x40	20	1	8	1-1/4x8-1/2	130	463.75
36	PWP-C36	38.30	5.50	49.04	38.00	46.88"	43.52"	12	1x40	24	1	8	1-1/4x8-1/2	130	520.40
42	PWP-C42	44.50	6.26	57.18	46.00	54.62"	50.62"	16	1 1/4x48	32	1 1/4	8	1 1/2x9	175	983.76
48	PWP-C48	50.80	6.26	63.48	46.00	60.92"	56.92"	16	1 1/4x48	32	1 1/4	24	1 1/2x9	175	1058.50

PV-LOK Products are rated with a working pressure equal to that of the PVC pipe to which they are applied. Also suitable for use on ductile iron pipe in sizes 4-12" (250 psi on 4"-8" and 200 psi on 10"-12") *When calculating clearance for pipe in a casing, add a minimum of 1-1/2" to the "B" dimension above.

Pressure Rating:

Nominal	Item #		Pressure Rating														
Pipe Size		C900										ASTM D2241					
		DR14	DR17	DR18	DR21	DR25	DR27.5	DR32.5	DR41	DR51	SDR17	SDR21	SDR26	SDR32.5	SDR41		
4	PWP-C4	305	250	235	200	165	150	-	-	-	250	200	160	125	100		
6	PWP-C6	305	250	235	200	165	150	-	-	-	250	200	160	125	100		
8	PWP-C8	305	250	235	200	165	150	-	-	-	250	200	160	125	100		
10	PWP-C10	305	250	235	200	165	150	-	-	-	250	200	160	125	100		
12	PWP-C12	305	250	235	200	165	150	-	-	-	250	200	160	125	100		
14	PWP-C14	305	250	235	200	165	150	125	100	-	-	-	-	-	-		
16	PWP-C16	305	250	235	200	165	150	125	100	-	-	-	-	-	-		
18	PWP-C18	305	250	235	200	165	150	125	100	80	-	-	-	-	-		
20	PWP-C20	305	250	235	200	165	150	125	100	80	-	-	-	-	-		
24	PWP-C24	305	250	235	200	165	150	125	100	80	-	-	-	-	-		
30	PWP-C30	-	250	235	200	165	150	125	100	80	-	-	-	-	-		
36	PWP-C36	-	-	235	200	165	150	125	100	80	-	-	-	-	-		
42	PWP-C42	-	-	-	200	165	150	125	100	80	-	-	-	-	-		
48	PWP-C48	-	-	-	-	165	150	125	100	80	-	-	-	-	-		





Installation Instructions (4-12"):

1. Assemble plain-end PVC pipe into bell according to pipe manufacturer's recommendations.

2. Assemble the Series PWP clamping rings on the spigot pipe (approx. 2 inches behind the insertion mark on the pipe) and immediately behind the pipe bell end, making sure the protrusions on the restrainer ears face toward each other to insure proper direction of the angled serrations. Tighten the side clamping bolts to recommended torque.

3. Insert the restrainer rods provided and snug the retaining nuts against the restrainer ears (against the flat surface). Do not overtighten retaining nuts, approximately one turn with a wrench.

Installation Instructions (14-48"):

1. Assemble pipe bell joint to pipe manufacturer's recommendations.

2. Assemble the Series PWP clamping rings on the spigot pipe approximately two inches behind the insertion mark on the pipe and immediately behind the pipe bell end. Tighten the side clamping bolts evenly to recommended torque – you should expect $\frac{1}{4}$ to $\frac{1}{2}$ gap on each side of the restrainer. The flat side of the restrainer ear should face away from the fitting to insure proper direction of the angled serrations.

3. Connect the two Series PWP restrainers using the restrainer rods that are provided. Place a washer behind each restrainer ear and snug all of the retainer nuts. Do not over-tighten retainer nuts, approximately one turn with a wrench.

AWWA Ductile Iron Fittings

LOCATIONS

Northeast Region

Cream Ridge, New Jersey (HQ) 700 Goldman Drive Cream Ridge, NJ 08514 Phone (800) 999-2550 Fax (609) 758-1158 crmcsr@sigmaco.com

REPCO

395 Boul. Labbé Nord Victoriaville, Qc G6P 1B1 Phone (888) 744-6262 Fax (819) 758-1153 jboucher@repco.ca

Concord Supply

2353 Bowman Street Innisfil, Ontario L9S 3V6 Phone (877) 436-3800 Fax (705) 436-6338 tanya@concordsupply.ca

Midwest Region

Sauk Village, Illinois 21699 Torrence Avenue Sauk Village, IL 60411 Phone (888) 999-0420 Fax (708) 758-6790 chicsr@sigmaco.com

Southeast Region

Alexander City, Alabama 1500 Highway 22 W Alexander City, AL 35010 Phone (800) 824-4513 Fax (256) 234-4956 alxcsr@sigmaco.com

Southwest Region

Houston, Texas 5000 Askins Lane Houston, TX 77093 Phone (800) 999-0109 Fax (281) 987-0200 htncsr@sigmaco.com

Western Region

Ontario, California 4652 E. Guasti Road Ontario, CA 91761 Phone (800) 688-6230 Fax (909) 391-2033 ontcsr@sigmaco.com

Auburn, Washington (Branch)

902 W Main Street Auburn, WA 98001 Phone (800) 688-6230 Fax (909) 391-2033 ontcsr@sigmaco.com

www.sigmaco.com

Terms and Conditions of Sales available at our website.



- 3-12" ONE-LOK SLC Wedge Restraint for PVC Pipe (Import)
- 3-60" ONE-LOK SLCE Wedge Restraint for PVC Pipe (Import)
- 3-42" ONE-LOK SLDEH Wedge Harness Restraint for Ductile Iron Pipe
- 4-12" /16" /20" ONE-LOK SLDM Wedge Restraint for Oversized Cast Iron Pipe
- 4-36" ONE-LOK SSLD Split Wedge Restraint for Installed Ductile Iron Pipe & Fitting
- 4-36" ONE-LOK SSLDH Split Wedge Harness Restraint for Installed Ductile Iron Pipe

• 4-48" PV-LOK PWM Serrated Restraint for Ductile Iron Fitting & AWWA C900/905 PVC Pipe

Line Card

• 4-12" ONE-LOK SLCEH Wedge Harness Restraint for AWWA C900 PVC Pipe

Visit our website for available special coatings. http://www.sigmaco.com/pipe-restraint-product-coatings-linings/

PV-LOK[™] Serration Lock Restraints



- 4-48" PV-LOK PWP Serrated Bell Joint Restraint for AWWA C900/905 PVC Pipe • 4-12" PV-LOK D-PWP Domestic Serrated Bell Joint Restraint for AWWA C900 PVC Pipe • 4-12" PV-LOK PWPF Restraint for AWWA C900/905 PVC Pipe & PVC Fitting • 4-12" PV-LOK PWH Serrated Harness Restraint for AWWA C900 PVC Pipe
 - 2-12" PV-LOK PVM Serrated Restraint for Ductile Iron & IPS OD PVC pipe
 - · 2-12" PV-LOK PVP Serrated Bell Joint Restraint for IPS OD PVC Pipe
 - 4-8" PV-LOK PVPF Serrated Restraint for IPS OD PVC Pipe & PVC Fitting
 - · 4-12" PV-LOK PWP Serrated Bell Joint Restraint for Ductile Iron Pipe

Visit our website for available special coatings. http://www.sigmaco.com/pipe-restraint-product-coatings-linings/

HDPE (Raven) Products



- · Optional White Interior Available Light & Medium Duty Load Capacities
- Extensive Nationwide Inventory
- · Rotational Molded Oil-Water Separators
- OEM Service Available
- **Municipal Construction Castings**
 - Manhole Rings and Covers
 - · Curb and Meter Boxes

 - · Valve Boxes, Risers, and Extensions

Products for the Ductile Iron Fabricator

- · 3-64" High Hub Threaded Flanges
 - 3-48" Tapped High Hub Threaded Flanges
 - 3-36" Extra Heavy 250lb Drilled Threaded Flanges

- Flange-Pak™ Prepackaged Flange Accessory Sets
- · Polyethylene Encasement for Ductile Iron Pipe
- Copper Tubing Products
- Tracer Wire & Detectable/Non-Detectable Marking Tape
- · Pipe Joint Lubricant & Hydraulic Cement
- · Socket Clamps and Tie Rod Accessories
- Boxlok Valve Box Alignment Device
- Cast Iron Companion Flanges

Flange Adapters



- · 3-36" SIGMAFLANGE Flange Adapter Sleeve for PVC and Ductile Iron Pipe
- 2-48" ZIP FLANGE Set Screw Style Flange Adapter
- 3-12" SIGMAFLANGE Universal Joint for Flanged Fittings, Flanged Pipes & Valves

TRIM-TYTON and TYTON are registered trademarks of the United States Pipe and Foundry Company • PROTECTO 401 is a registered trademark of Induron, Inc.

- Frames and Grates Storm Inlets
 - 3-48" Threaded MJ Bell Adapters
 - 3-48" MJ x PE Bell adapter · 3-48" Anchor Flanges
 - 3-16" Filler Flanges

Extended Range Products

